



# CERTIFICATE

Certificate No. : ZYGA-2022-003

Certificate Holder: Shenzhen Jiwei Automations Ltd.

Address: 501, Longgang Avenue NO.3162, Liuyue Community, Henggang Street, Longgang District, Shenzhen

Manufacture: Shenzhen Jiwei Automations Ltd.

Address: 501, Longgang Avenue NO.3162, Liuyue Community, Henggang Street, Longgang District, Shenzhen

Factory: Shenzhen Jiwei Automations Ltd.

Address: 501, Longgang Avenue NO.3162, Liuyue Community, Henggang Street, Longgang District, Shenzhen; 101, Building No. 12, 8th Liuhe Road, Tangkeng Community, Henggang Street, Longgang District, Shenzhen

## Product

Magnetic Level Indicator Flap-11 Series

## Codes & Standards

IEC 61508-1:2010, IEC 61508-2:2010, GB/T 20438.1-2017, GB/T 20438.2-2017

## Certification Conclusion

Can apply to SIL 2 (HFT=0), SIL 3 (HFT=1) safety application

## Certification Scheme & Scheme Type

ZYGA-GZ-01 A/2 Functional safety certification scheme,

Functional safety assessment + Product type testing + Initial factory inspection + Regular surveillance

The product is compliance to functional safety certification scheme of Instrumentation Technology and Economy Institute, P.R.China (ITEI). The validity of certificate should be maintained according to regular surveillance of certification body during the validity period of certificate. The certificate is initially issued on 2023-06-12, the status of this certificate can be tracked on [www.fs-china.org](http://www.fs-china.org). The issued certificate is based upon an examination, whose result is documented in Report No. ZYGA-2022-FSA-003.

Issued date  
2023-06-12

Expired date  
2028-06-12



Instrumentation Technology and Economy Institute, P.R.China (ITEI)

No.397A, Guang'anmenwai Street, Xicheng District, Beijing, China  
Tel: 010-63261819 Web: [www.itei.cn](http://www.itei.cn)